

एकलव्य आदर्श आवासीय विद्यालय कोलागल्लु
तालुक - बल्लारी, जिला - बल्लारी, कर्नाटक
पिन कोड - 583104
राष्ट्रीय आदिवासी छात्र शिक्षा समिति
जनजातीय कार्य मंत्रालय, भारत सरकार
सीबीएसई संबद्धता न. - 820086
युडाईस कोड - 29120105614
मोबाइल न. - 7309448010
ईमेल - kreisemrs253@gmail.com



EKLAVYA MODEL RESIDENTIAL SCHOOL KOLAGALLU
TQ. - BALLARI, District - BALLARI, KARNATAKA
PIN CODE - 583104
National Education Society for Tribal Students (NESTS)
Ministry of Tribal Affairs, Government of India
C.B.S.E.Affiliation No. - 820086
Udise Code - 29120105614
Mobile No. - 7309448010
Email - kreisemrs253@gmail.com

F. No. - KESTS/EMRS/2025-26/575

Date: 26-03-2026

To
The Executive Engineer (E)-II
CPWD Bangalore
Karnataka

Sub: Request for the Estimate for Installation of Fire Safety Infrastructure at EMRS
Kolagallu - reg.

Ref: 1). Fire Safety Recommendation Certificate No. 13/RFO/Low Rise/Ballari/2026,
Dated: 13/02/2026.

2). Challan Reference No. CR0226007000055108, Dated: 04/02/2026

Respected Sir,

With respect to the subject cited above, it is requested you to provide the estimation for Installation of Fire Safety Infrastructure at EMRS Kolagallu. The District Fire Officer inspected the school premises on 08/01/2026. Following this inspection, the Regional Fire Officer, Ballari Range, has issued a "Fire Safety Recommendation Certificate" detailing the mandatory fire prevention and fighting measures required for our premises.

To comply with these directives and obtain the final Fire Compliance Certificate, we require the installation of specific infrastructure. We request your office to provide a detailed estimate and quotation for the execution of the works as per the fire department's recommendations.

The fire department has mandated that these compliance measures must be implemented within 03 months from the date of the certificate's issue (13/02/2026). Therefore, we request you to kindly provide the quotation so that we can proceed with the necessary administrative approvals and fund allocation at the earliest.

This is for your kind consideration and necessary action at your end please.

Principal

Eklavya Model Residential School
Kolagallu, Ballari Dist, Karnataka.-583104

With Regards

Encl.: 1). Fire Safety Recommendation Certificate No. 13/RFO/Low Rise/Ballari/2026,
Dated: 13/02/2026.

2). Challan Reference No. CR0226007000055108, Dated: 04/02/2026



Karnataka State Fire and Emergency Services

Office Of the Regional Fire Officer, Ballari Range,
Infantry Road, Ballari.

Tele No. 08392- 266933, E-mail :- rfoballari.ksfes@nic.in



C.No. 13/RFO/Low Rise/Ballari/2026

Dated : 13/02/2026

To,

The Principal
Ekalavya Model Residential School
Kolagallu Village, Ballari Taluk,
Ballari Dist.

Sir,

Sub: Issue of "Fire Safety Recommendation Certificate" for the Constructed & Occupied Hostel & Educational Buildings by "**Ekalavya Model Residential School**" Located at Kolagallu Village, Ballari Taluk, Ballari Dist.

Ref : 1) Your letter dated : 11/12/2025.

2) Inspection report No. 304/DFO/Ballari/2025-26, Dated : 16/01/2026.


With reference to the subject cited above, the District Fire Officer, Ballari Fire station, Ballari District, has inspected the Hostel & Educational constructed & occupied by "**Ekalavya Model Residential School**" Located at Kolagallu Village, Ballari Taluk, Ballari Dist. On 08/01/2026 with respect to fire prevention, fire fighting and evacuation measures to be complied in the above premises and submitted the details as follows:-

"A3 Hostel Building & B Educational Building"

(These condition are indicative and not exclusive all relevant provisions related to fire and life safety of NBC 2016 are mandatory)

A. Details of the building / premises :-

01	Name and Address of the Applicant.	:	The Principal Ekalavya Model Residential School Kolagallu Village, Ballari Taluk, Ballari Dist.
02	Name and Address of the premises.	:	Ekalavya Model Residential School Kolagallu Village, Ballari Taluk, Ballari Dist.
03	Name and address of the Building owner	:	Ekalavya Model Residential School Kolagallu, National Education Society for Tribal Students Government of India.
04	Number of buildings	:	04 Buildings, i.e., Block-I, Block-II, Block-III & Block-IV



05	Number of floors	: Block I- Academic Block, Ground+01 Upper Floor Block II- Dormitory, Ground Floor (Boys Hostel) Block III- Dormitory, Ground Floor (Girls Hostel) Block IV- Kitchen & Dinning Block, Ground Floor.
06	Floor-wise details of occupancy:-	
Block I Academic Block		: <u>Ground floor</u> 4 Class Rooms, 1 Biology Lab, 1 Chemistry Lab, 1 Physics Lab, 1 Principal Room, 1 Staff Room, 1 Office Record Room, 1 Computer Room, 1 Boys Toilet and Ladies Toilet. <u>1st floor</u> 10 Class Rooms, 1 Library Room, 1 Stores / Sports Room, 1 Boys Toilet and Ladies Toilet.
Block II Dormitory, (Boys Hostel)		: <u>Ground floor</u> 12 Rooms, 1 Warden Room, 1 Common Room, 1 Recreation Room and 2 Bath Room/ Toilet Rooms.
Block III Dormitory, (Girls Hostel)		: <u>Ground floor</u> 12 Rooms, 1 Warden Room, 1 Common Room, 1 Recreation Room and 2 Bath Room/ Toilet Rooms.
Block IV Kitchen & Dinning Block		: <u>Ground floor</u> 1 Dinning Hall, 2 Hand Wash Areas, 2 Store Rooms, 1 Pantry, 1 Dry Store Room, 1 Dish Store Room, 1 Kitchen Room, 1 Dish Wash Room, 1 Water Storage Area and Bath Room.



07	Height of the building	: Block I Academic Block- 08.00 Mtrs Block II Dormitory, (Boys Hostel) 03.30 Mtrs Block III Dormitory, (Girls Hostel) 03.30 Mtrs Block IV Kitchen & Dinning Block 03.30 Mtrs
08	Site area	: 39,659.00 Sq Mtrs
09.	Built-up area of each floor:-	: Block I Academic Block <u>Ground floor</u> 1,118.98 Sq Mtrs. <u>1st floor</u> 1,085.44 Sq Mtrs. Block II Dormitory, (Boys Hostel) <u>Ground floor</u> 993.32 Sq Mtrs. Block III Dormitory, (Girls Hostel) <u>Ground floor</u> 993.32 Sq Mtrs. Block IV Kitchen & Dinning Block <u>Ground floor</u> 451.58 Sq Mtrs.



10.	Total built-up area	:	4,642.64 Sq Mtrs.
11.	Surrounding properties:-		
	East	:	KEB Substation
	West	:	09 Mtrs Wide Ballari to Kurugodu Road
	North	:	Open Land
	South	:	Agricultural Land
12.	Set-back area available around the building :-		
	Block I Academic Block		Recommended: To provide as per Local Zonal Regulations.
	East	: 03.00 Mtrs	
	West	: 10.00 Mtrs	
	North	: 06.00 Mtrs	
	South	: 10.00 Mtrs	
	Block II Dormitory, (Boys Hostel)		
	East	: 07.00 Mtrs	
	West	: 15.00 Mtrs	
	North	: 06.00 Mtrs	
	South	: 10.00 Mtrs	
	Block III Dormitory, (Girls Hostel)		
	East	: 05.00 Mtrs	
	West	: 10.00 Mtrs	
	North	: 15.00 Mtrs	
	South	: 03.30 Mtrs	
	Block IV Kitchen & Dinning Block		
	East	: 15.00 Mtrs	
	West	: 03.00 Mtrs	
	North	: 06.00 Mtrs	
	South	: 03.30 Mtrs	

B. On inspection of this Hostel & Educational premises, the following fire prevention, fire fighting and evacuation measures recommended are considered absolutely essential from fire safety point of view :-

Sl. No. [01]	Details [02]	Existing [03]	Recommendations [04]
01.	Accessibility to the premises	The Premises is Accessible From 09.00 Mtrs Wide Ballari to Kurugodu road, located on the western side and the road is hardened to carry the weight of 45,000 kgs.	Adequate



02	No of entrances.	01 No.				
03	Width of Entry/ Exit	04.00 Mtrs.			Recommended to widen the existing Entry / Exit Width of 06.00 mtrs.	
03	No. of staircases available	No of staircase	: 01 No. Block-I	02 No's Block-II	02 No's Block-III	Recommended to provide one more staircase for Block-I width of 01.50 Mtrs. at strategic location to meet travel distance as per NBC 2016.
	Width of staircase	:	02.00 Mtr	01.50 Mtr	01.50 Mtr	
	Width of treads	:	30 Cms	30 Cms	30 Cms	
	Height of risers	:	15 Cms	15 Cms	15 Cms	
	No of riser per flight	:	13 Risers	13 Risers	13 Risers	
	Height of handrails	:	01.00 Mtrs	01.00 Mtrs	01.00 Mtrs	
04	No. of ramps and width	No. of ramps	: 01 No.			
		Width of ramps	: 02.00 Mtrs			
05	Fire extinguisher	Provided 02 No's of 04 Kg ABC Fire Extinguishers.			<p>01) 01 No ABC Fire Extinguisher each of 6 kg capacity Should be Located As Available Within 15 Mtrs Radius. in each floor & Each Block.</p> <p>02) 01 No of CO2 Fire Extinguisher of 4.5 kg capacity Should be Provided near each Electrical Panel Board And Electrical Room. Switch board.</p> <p>03) 01 Mechanical Foam Extinguishers of 09 ltrs Capacity and 01 ABC type Extinguishers of 6 kg capacity should be provided near diesel Generator.</p> <p>04) 01 DCP Extinguishers of 4 kgs</p>	



			<p>capacity Should be provided in the Kitchen if Provided for the purpose of mid day meal.</p> <p>05) Two number of Hand gloves near the Electrical Switch board.</p> <p>[All the extinguishers suggested above should be with B.I.S. markings and should be located at an easily accessible position without obstructing the normal passage and maintained periodically].</p>
06	Hose reel hose system.	Not Provided.	<p>Recommended to provide Hose reel hose Near the Staircase (one hose Reel hose System for every 1000 Sq. Mtrs) The hose Reel of 30 mtr length with drum and 01 no's delivery hose pipes minimum 2 ½ inch size of adequate length to reach the farthest point of each floor has to be provide with a shut off branch having a nozzle of 2 mm size. The hose reel hose has been connected at each.</p>
07	At the terrace tank level with minimum pressure of 3.5kg/cm ²	Not Provided.	<p>Recommended to provide 04 No's pump with minimum pressure of 450 LPM. (Further the system should be connected to an alternative source of power supply).</p>
08	Diesel generators.	Not Provided.	<p>Recommended to Provide One Adequate capacity of Generator and It should be connected to alternative power supply for staircases lighting corridor lighting and lifts, etc., in the event of failure of electricity supply in the building.</p>
09	Terrace tank	Provided 03 No's of 2000 Ltrs Capacity Syntax Tank.	<p>Recommended To Provide 01 Over Head Tank of 10,000 Ltrs Capacity for Block-I & 01 Over Head Tank of 5,000 Ltrs Capacity for each Block-II, III & IV.</p>
10	Fire control room at ground floor.	Not Provided.	<p>Recommended to Provide separate fire control room at ground floor nearby staircase.</p>
11	Escape routes	Not Marked.	<p>Signage board is required with illuminated points for in which direction to go outside from the building for staff & students and also separate light arrangement to the illumination board by doing from battery operated</p>

l
13/02

12	Fire order (Fire Safety Plans)	Not Displayed	The Notice board have been indicted the action should be taken by the employees in case of any emergency should be displayed with the telephone number Ballari fire Station i.e. 08392-266001 & 112 , and the telephone number of nearest Ambulance services and Police Station.
13	No Smoking Board	Not Displayed	COTPA Sec-4 Direction No Smoking area Smoking hear is an offence Board Should be written in English & Kannada both language Shall be Prominently displayed at inside the Entry/Exist of Each Floor.
14	Fire Siren	Not Installed	A fire Siren shall be installed in the premises to inform the inmates in case of a fire emergency/evacuate the area
15	Nominate one fire Nodal officer	-	A fire nodal officer shall be nominated either from teaching or no teaching staff.
16	Fire fighting training.	Not Imparted	At-least 40% of School Staff should be got trained in basic fire fighting at R.A.Mundkur fire & Emergency Services Academy, Bannerughatta road, Bangalore within 3 months or at an early date.
17	<p>Fire Precautionary Measures:</p> <ol style="list-style-type: none"> 1) Explosive and flammable materials should not be stored in the store room, UPS room, Electrical panel area, class rooms, laboratory and electrical cum panel premises. 2) Accumulation of combustible waste in and around the premises should be avoided. 3) The exit ways shall be always kept clear without any Obstruction. 4) Liquefied petroleum gas should not be stored in the building. 5) The doors shall not be kept locked / latched during working hours and shall be free from obstruction. 6) During the class hours the class room doors shall not be locked from inside to outside. 7) As per Honorable supreme court order all teachers and staffs shall be trained to handle safety equipment, initiate emergency evacuation and protect their students in the event of fire and other emergency and the school shall observe the fire safety day on 14th of every year by conducting fire safety drills with co-ordinate with fire service department. 		

As such the Karnataka State Fire and Emergency Services department is issuing **Fire Safety Recommendation Certificate** for the Hostel & Educational Buildings by "**Ekalavya Model Residential School**" Located at Kolagallu Village, Ballari Taluk, Ballari Dist. from Fire prevention, Fire fighting and Evacuation point of view. Subject to the compliance of recommendations mentioned above within 03 months from the date of issue of Fire Safety Recommendation Certificate.



Note:

1. This is only the "Fire Safety Recommendation certificate" issued by the Fire Department from fire safety view of the low-rise already constructed Building. This shall not be considered as No Objection Certificate for the building.
2. After completion of all the fire fighting installations as advised in Fire Safety Recommendation certificate, 'Fire Compliance Certificate' shall be obtained from the Fire and Emergency department.
3. This "Fire Safety Recommendation certificate" is valid for a period of one year only from the date of issue.

Yours faithfully,


**Regional Fire Officer
Karnataka State Fire And
Emergency Service
Ballari Range, Ballari.**

Copy with Respect :-

1. The Director General of Police and Director General, Karnataka State Fire & Emergency Services, Bengaluru.

Copy To:

1. The District Fire Officer, Ballari Fire Station, Ballari Dist.

Printer's copy



ಚಲ್ಲಾನ್ ಅನುಮತಿ Challan Validity	ಜಿಲ್ಲೆ District	ಇಲಾಖೆ Department	ದಿವಿಡನ್ ಕಛೇರಿ DDO Office	
7 Days	BALLARI	DEPARTMENT OF KARNATAKA FIRE & EMERGENCY SERVICES	DIVISIONAL FIRE OFFICE, BELLARY ZONE, KARNATAKA FIRE & EMERGENCY SERVICES, BELLARY	
ವರ್ಗ Category	ದಿನಾಂಕ Date	ಚಲ್ಲಾನ್ ಸಂಖ್ಯೆ Challan Reference Number	ದಿವಿಡನ್ ಕೋಡ್ DDO Code	
Government	04/02/2026	CR0226007000055108	140280	
ಪಾವತಿದಾರನ ಹೆಸರು Remitter Name	EKALAVYA MODEL RESIDENTIALSCHOOL		ಮೊಬೈಲ್ ಸಂಖ್ಯೆ Mobile Number	1111111111
ವಿಳಾಸ Address	Kolagallu Village, Ballari Taluk, Ballari Dist.			
ಉದ್ದೇಶ Purpose	ಲೆಕ್ಕ ಶೀರ್ಷಿಕೆ Head of Account	ಉಪ ಉದ್ದೇಶದ ಹೆಸರು Sub Purpose Name	ಉದ್ದೇಶ ನಿರ್ದಿಷ್ಟ ಐಡಿ Purpose Specific ID	ಮೊತ್ತ Amount
COLLECTION OF FEES AND OTHER RECEIPTS FROM FIRE DEPARTMENT	0070-60-109-0-02-000	12.FOR ISSUE OF ADVISE ON FIRE PREVENTION AND FIRE FIGHTING FOR NON HIGH RISE BUILDINGS.	NA--	55000
ಪಾವತಿಯಾದ ಬ್ಯಾಂಕ್ Remittance Bank	STATE BANK OF INDIA	ಒಟ್ಟು ಮೊತ್ತ Grand Total	55000	
ಪಾವತಿ ಹಂತ Payment Status	Payment Yet To Be Made At Agency Bank	ಒಟ್ಟು ಮೊತ್ತ ಅಕ್ಷರಗಳಲ್ಲಿ Total Amount in Words	Fifty Five Thousand Only	
ಪಾವತಿ ವಿವರಗಳು Payment Details				
ಪಾವತಿ ವಿಧ Payment Mode	Cheque/Draft			
ಚೆಕ್/ಡಿಡಿ ಸಂಖ್ಯೆ Cheque/DD No	ಚೆಕ್/ಡಿಡಿ ಬ್ಯಾಂಕ್ Cheque/DD Bank	ಐ.ಎಫ್.ಎಸ್.ಸಿ ಕೋಡ್ IFSC Code	ಮಿಕ್ರೋ ಕೋಡ್ MICR Code	ಚೆಕ್/ಡಿಡಿ ದಿನಾಂಕ Cheque/DD Date
997	STATE BANK OF INDIA	SBIN000081	583002999	04/02/2026

JM-166688490

BI
RECEIVED
11 FEB 2026
NARASIPUR
PF No. 72861

Signature

Principal
Eklavya Model Residential School
Kolagallu, Ballari Dist. Karnataka-583104



भारतीय स्टेट बैंक
State Bank Of India

(00817) - BALLARI MAIN
SBI BUILDINGS, RAILWAY STATION ROAD BALLARI
DIST BALLARI, KARNATAKA 583101
Tel: 8392-271188 Fax: 9480693545 IFS Code: SBIN000817

शुद्ध + मूल्य के लिए ही / VALID FOR MONY ONLY
0 4 0 2 2 0 2 6
O O M M Y Y Y Y

PAY Yourself

रुपये RUPEES Fifty five Thousand only/-

अदा करें ₹ 55,000/-

NE. W. A/c No. 39587207736

VALID UP TO ₹ 10 LACS AT NON-HOME BRANCH FOR NON-CASH TRANSACTION ONLY

63770278593

SB ACCOUNT

PREFIX:
1515500018

Om Prakash
Senior Most Teacher
Eklavya Model Residential School
Kolagalku, Ballari Dist, Karnataka-583104

Sanil

EKLAVYA MODEL RESIDENTIAL SCHOOL KOLAGAL

MULTI-CITY CHEQUE Payable at Pa

Please sign above
Principal
Eklavya Model Residential School
Kolagalku, Ballari Dist, Karnataka-583104

354997 583002101: 026993* 31

04-09-2025

राष्ट्रीय आदिवासी छात्र शिक्षा समिति

(जनजातीय कार्य मंत्रालय के अंतर्गत
एक स्वायत्त संस्थान, भारत सरकार)
भू-तल, गेट नंबर-3ए, जीवान तारा बिल्डिंग,
पार्लियामेंट स्ट्रीट, नई दिल्ली-110001
दूर. 011-23340280



National Education Society for Tribal Students

(An Autonomous Organization under
Ministry of Tribal Affairs, Govt. of India)
Ground Floor, Gate No.3 A, Jeevan Tara Building,
Parliament Street, New Delhi-110001
Telephone No. 011-23340280
वेबसाइट/Website: www.tribal.nic.in
Email: nests-tribal@tribal.gov.in

F.No. NESTS/Admin/Recurring-Karnataka/129/2021-22

date: 15.04.2026

To,
The Principal,
EMRS Kollagalu, Karnataka

Subject: Request for administrative approval and sanction of funds for the installation of Fire Safety infrastructure to obtain the mandatory Fire Safety Certificate - reg.

Madam/Sir,

Kindly refer to your letter No. KESTS/EMRS/2025-26 dated 24.03.2026, wherein administrative approval and sanction of funds is requested for the installation of fire safety infrastructure to obtain the mandatory Fire Safety Certificate.

2. In this regard, it is informed that as per the recurring cost guidelines issued on 01.05.2025, the school may utilize funds from contingencies under Operational Expenditure and Co-Curricular Activities for carrying out the necessary actions for obtaining the certificate.

This issues with the approval of the competent authority.

(Gaurav Pawar)

Deputy Commissioner (Finance)

Copy for information:

1. PS to Commissioner, NESTS
2. Nodal officer, KESTS.
3. Consultant (HR), Karnataka, NESTS.



GOVERNMENT OF KARNATAKA

R.A. MUNDKUR FIRE AND EMERGENCY SERVICES ACADEMY
BANNERUGHATTA ROAD, BENGALURU - 560 029.

-----<<<<<>>>>>-----

This is to certify that *Shri/Smt. NAVEEN KUMAR.R.TGT ART. Eklavya Model Residential School, Kolagallu, Ballari, has under-gone basic training in fire prevention and fire fighting from 26-03-2026 to 27-03-2026 [2 days] at R.A.Mundkur Fire And Emergency Services Academy, Bengaluru - 560029.*

Date: 27-03-2026
Place: Bengaluru

Commandant
R.A. Mundkur Fire & Emergency Services
Academy, Bannerughatta road,
Bengaluru - 560 029.

No. 2026 03 0772



107

